



CITY OF CLEARWATER

POST OFFICE BOX 4748, CLEARWATER, FLORIDA 33758-4748
TELEPHONE (727) 562-4334

FIRE DEPARTMENT

September 10, 1999

Mr. Larry Pence
Pence Marketing Group

Dear Mr. Pence:

This agency conducted an evaluation of the Quick n' Crispy Greaseless Fryer, model GF-II, on September 10, 1999. During the evaluation, precooked food products were heated up to the point where they were blackened. It did not appear that any grease or smoke vapors were emitted during the cooking process. Based upon the results of the evaluation, Quick n' Crispy Greaseless Fryers, model GF-II will be permitted in food facilities within Clearwater Fire District without mechanical exhaust ventilation under the following conditions:

1. Only precooked food products may be heated up in the unit.
2. A decal is prominently displayed on the fryer stating that only precooked products may be warmed up in the unit.
3. The unit must be installed and operated according to manufacturer's specifications.
4. The unit must be installed in a well-ventilated area of the food facility.

If this agency determines that the equipment is generating grease or smoke vapors, or if it is not being operated in accordance with the conditions contained in this letter, the installation of an approved mechanical exhaust ventilation system or the removal of the unit from the premises will be required.

This letter is for documentation purposes only, and is not to be construed as an endorsement of the product.

Please contact me if you have any questions regarding this matter, 727-562-4327, ext. 3078.

Sincerely,

A handwritten signature in cursive that reads "Randy Hinder".

9/10/99

Randy Hinder
Fire Marshal
Clearwater Fire & Rescue

ONE CITY. ONE FUTURE.

BRIAN J. AUNGST, MAYOR-COMMISSIONER

ED HOOPER, VICE MAYOR-COMMISSIONER
ED HART, COMMISSIONER



BOB CLARK, COMMISSIONER
J.B. JOHNSON, COMMISSIONER

"EQUAL EMPLOYMENT AND AFFIRMATIVE ACTION EMPLOYER"